

KINGDOM OF CAMBODIA

NATION RELIGION KING



DECISION ON RENEWAL TERM OF THE CONSOLIDATED LICENSE No. 039 LD FOR MR. KIM CHANTARA

ELECTRICITY AUTHORITY OF CAMBODIA

- In exercise of the powers conferred by Article 7 and 35 of the Electricity Law promulgated by the Royal Decree NS/RKM/0201/03, dated 02/02/2001.
- In accordance with License Documents No. 039 LD issued by Electricity Authority of Cambodia on May 20, 2003 to Mr. Kim Chantara
- In accordance with the application for renewing term of license of Mr. Kim Chantara dated April 27, 2005.
- In accordance with the request for renewal term of Secretariat Office N°019-05-SO dated May 10, 2005.
- In accordance with the consultation with concerned parties and public, made from May 25, 2005 to June 13, 2005.
- In accordance with the decision of Electricity Authority of Cambodia's Session No. 53, Dated June 30, 2005.

DECIDES

Article 1

As **Mr. KIM CHANTARA** has improved some of his facilities and he has to improve further in coming years to meet the General Requirements of Electric Power Technical Standards of the Kingdom of Cambodia, EAC decides to revise license No. 039 LD dated May 20, 2003 granted to **Mr. KIM CHANTARA** by renewing his final test term of license for 2 years.

Article 2

The final test term of the license shall be 2 years from May 20, 2005 and may be renewed for further periods unless revoked earlier in accordance with the conditions of license.

Article 3

This decision is the part of the license document No. 039 LD.

Article 4

The other contents and conditions of the license document No. 039 LD shall remain in force.

Article 5

The decision shall come into force from the date of signing.

Article 6

The licensee shall send this decision to deposit additionally at the places, where the license document No. 039LD has been deposited in order that the deposited license document No. 039LD is in conformity with this decision.

Phnom Penh, June 30, 2005

CHAIRMAN OF ELECTRICITY AUTHORITY OF CAMBODIA

SCHEDULE 2
EXISTING GENERATING FACILITIES OF THE LICENSEE

A. Licensee's Generation Facilities

Licensee's Generator House

1. The licensee's generator house is constructed by wood wall and zinc roof with size of 8 x 8 meters, located at Phum Thnal Cheat, Khum Baray, Baray District, Kampong Thom Province.

General Specifications of the Generators

1. The licensee has 02 units of generators with the total installed capacity of 70 kVA:
 - 1st Generator: installed capacity 50kVA
 - 2nd Generator: installed capacity 20kVA
2. The normal fuel for the generators is Diesel Oil (DO).

This condition of the licenses the same as license No 15 LD, issued on November 22, 2002 if you would like to see, please go through the part two of this license.