

KINGDOM OF CAMBODIA

NATION RELIGION KING



DECISION ON THE RENEWAL TERM OF THE CONSOLIDATED LICENSE DOCUMENT No. 043 LD, DATED JULY 01, 2003 FOR Mr. LAY SE

ELECTRICITY AUTHORITY OF CAMBODIA

- In exercise of the powers conferred by Article 7 and 35 of the Electricity Law promulgated by the Royal Decree NS/RKM/0201/03, dated 02/02/2001.
- In accordance with License Documents No. 043 LD issued by Electricity Authority of Cambodia on July 01, 2003 to Mr. LAY SE.
- In accordance with the application for renewal term of Mr. LAY SE dated May 10, 2005
- In accordance with the request for renewal term of Secretariat Office N°021-05 dated May 17, 2005.
- In accordance with the consultation with concerned parties and public, made from May 31 , 2005 to June 27, 2005 .
- In accordance with the decision of Electricity Authority of Cambodia's Session No. 53, dated June 30, 2005.

DECIDES

Article 1

As **Mr. LAY SE** has improved some of his facilities and he has to improve further in coming years to meet General Requirements of Electric Power Technical Standards of the Kingdom of Cambodia, EAC decides to revise license No. 043 LD dated July 01, 2003 granted to **Mr. LAY SE** by renewing his final test term of license for 2 years.

Article 2

The final test term of the license shall be 2 years from July 01, 2005 and may be renewed for further periods unless revoked earlier in accordance with the conditions of license.

Article 3

This decision is the part of license of the license document No. 043 LD.

Article 4

The other contents and conditions of the license document No. 043 LD shall remain in force.

Article 5

The decision shall come into force from the date of signing.

Article 6

The licensee shall send this decision to deposit additionally at the places, where the license document No. 043LD has been deposited in order that the deposited license document No. 043LD is in conformity with this decision.

Phnom Penh, June 30, 2005
CHAIRMAN OF ELECTRICITY AUTHORITY OF CAMBODIA

SCHEDULE 2
EXISTING GENERATING FACILITIES OF THE LICENSEE

A. Licensee's Generation Facilities

Licensee's Generator House

1. The licensee's generator is located at Phum Thmor Kol, Khum Tapoung, Thmor Kol District, Battambang Province.

General Specifications of the Generators

1. The licensee has 03 units of generators with the total installed capacity of 440 kVA:

-1st Generator : installed capacity 200kVA

-2nd Generator : installed capacity 160kVA

-3rd Generator : installed capacity 80kVA

2. The normal fuel for the generators is Diesel Oil (DO).

This condition of the licenses the same as license No 15 LD, issued on November 22, 2002 if you would like to see, please go through the part two of this license.