

KINGDOM OF CAMBODIA

NATION RELIGION KING



DECISION ON EXTENDING THE TERM OF THE CONSOLIDATED LICENSE NO . 018 LD ISSUE TO Mr. KY SOPHEAR

ELECTRICITY AUTHORITY OF CAMBODIA

- In exercise of the powers conferred by Article 7 and 35 of the Electricity Law promulgated by the Royal Decree No. NS/RKM/0201/03 dated 2 February 2001.
- Refer to the Consolidated License Document of Mr. Ky Sophear No.018 LD dated November 29, 2002
- In accordance with the application for extending the term of Mr. Ky Sophear, dated July 07, 2004.
- In accordance with the decision of Electricity Authority of Cambodia's Session No.43 dated November 30, 2004

DECIDES

Article 1

EAC decides to extend license No. 018 LD dated November 29, 2002 granted to Mr. Ky Sophear for providing electric power generation and distribution services at phsar snaypul town located in districts of pea rang, prey veng province.

Article 2

As Mr. Ky Sophear has improved some of his facilities and he has to improve further in coming years to meet the Technical Standard, EAC decides to extend the term of license for a test period. The term of license is intended for 3 years (Three) from the date of signing and may be renewed for further periods unless revoked earlier in accordance with the conditions of license.

Article 3

This decision shall be a part of license No. 018 LD.

Article 4

The other contents and conditions of the license No. 018 LD shall remain unaltered and in force.

Article 5

The decision shall come into force from the date of signing.

Article 6

The licensee shall send this decision to deposit additionally at the places, where the license document No. 018 LD has been deposited in order that the deposited license document No. 018 LD is in conformity with this decision.

Phnom Penh, November30, 2004

CHAIRMAN OF E A C

SCHEDULE 2

EXISTING GENERATING FACILITIES OF THE LICENSEE

A. Licensee's Generator House

1. The Licensee's generator house is constructed by wood, tile roof with size of 4 x 6 meters; locate at Phum Snaypul, Khum Roka, Pearang District, Prey Veng Province.

B. General Specifications of the Generators

1. The licensee has 02 units of generators with the total installed capacity of 345kVA:
 - Generator made in Korea, Capacity 200 kVA 1unit
 - Generator made in Soviet, Capacity 75 kVA 1unit
 - Generator made in China, Capacity 35 kVA 1unit
 - Generator made in Soviet, Capacity 35 kVA 1unit
1. The normal fuel for the generators is Diesel Oil (DO).

This condition of the licenses the same as license No 15 LD, issued on November 22, 2002 if you would like to see, please go through the part two of this license.

